

Pre-Bid Clarification**Tender No** TPCODL/P&S/100000081/2021-22**Package Name** OPEN TENDER NOTIFICATION FOR SUPPLY OF AB SWITCH 33KV (200 AMP AND 400 AMP) & 11KV (200 AMP AND 400 AMP)**Note :**

Sr. No.	Detailed Reference to Tata Power Tender Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	Tata Power Response
1	2	3	4	5
1	Document no : 4 ,clause no : 35,page no :5 of technical specification of 33 kv 400 amp ab switch	Operating Down Pipe , B Class : 32mm Dia & 7 Mtr Long	standard size is 32 mm dia & 6 Mtr Long	Pipe shall be B Class - 32mm Dia NB & 7 Mtr Long without any joints as IS 1239.
2	Document no : 4 ,clause no : 28,page no :20 of technical specification of 11 kv 200 amp & 400 amp ab switch	Operating Down Pipe , B Class : 32mm Dia & 7 Mtr Long	standard size is 32 mm dia & 6 Mtr Long	Pipe shall be B Class - 32mm Dia NB & 7 Mtr Long without any joints IS 1239.
3	Document no : 1.7 ,clause no : d,page no :6 of qualification criteria	Bidder must have successfully executed the supply of 33kV AB Switch 400 Amp for a minimum 100 Qty. or more in single order. 33kV AB Switch 200 Amp for a minimum 50 Qty. or more in single order. 11kV AB Switch 400 Amp for a minimum 100 Qty. or more in single order. 11kV AB Switch 200 Amp for a minimum 200 Qty. or more in single order within last 5 Year. Copy of completion certificates to be submitted in this regard	If we have experience of higher rating ,will it cover lower rating of material in qualification criteria.	Supply of 33 KV or 11 KV Ab switch with 200A or 400 A or higher rating is acceptable. Supplied quantity and duration of supply shall be as per Document no : 1.7 ,clause no : d,page no :6 of qualification criteria