

Tender No. TPCODL/P&S/1000000189/21-22
"Electrification of UEHs by providing Service Connection under PMAY-G and BGJY schemes"

Replies to Pre-Bid Queries_2

S. No.	Clause no / Page No.	Description	Bidders query / Clarification	TPCODL Response / Modification
1	Annexure VII, Scope of Work; New Connection Service Kit, Page 27	Single point wiring Wooden / Fiber Glass Reinforced Polyester sheet mounted compound (SMC) Board { 200 X 150 X 40 mm (minimum)} for installing internal electrification	In the BOQ SMC box is mentioned but in the specs it is a polycarbonate box? Pl specify which box is required?	Polycarbonate Box is required
2	ANNEXURE VIIa, Preferential Norms for MSME, Page 29	Qualification Requirement for Open Tenders Qualification Requirement of Financial Turnover for MSME registered in the State of Odisha shall be reduced to 20% of the existing criteria. For past experience, instead of relying on the volumes / value of earlier Supplies / Projects, assessment of the Bidder shall be done on the basis of feedback from Customers. Past performance experience at Tata Power and its Group Companies shall supersede feedback from other Customers.	Please specify the quantum of work done required from MSME odisha unit.	As per tender; For past experience, instead of relying on the volumes / value of earlier Supplies / Projects, assessment of the Bidder shall be done on the basis of feedback from Customers. Past performance experience at Tata Power and its Group Companies shall supersede feedback from other Customers.
3	7.5 Payment Terms, Page 14	90 % payment shall be released within 30 days of bill submission at designated desk. b. 10% payment shall be released after safety, quality parameter and material reconciliation verification by EIC or within 60 days from receipt of bill, if no issue is reported by EIC, whichever is earlier	Other discoms are paying 70% of material Value against receipt of materials but in tender documents it is not specified.	As per tender