

Format for Pre-Bid Queries

Tender Reference No	TPCODL/P&S/100000213/2022-23
Tender Name	Supply of Transformer Oil
Bidder Name :	

Note : Pre-Bid Query has to be sent in editable Excel file format only

Sr. No.	Detailed Reference to TPCODL Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPCODL Response
1	2.1	P0 = Price (in Rs / KLtr) quoted/ confirmed for the transformer oil supplied in drums and conforming to IS : 335-1993 and amended from time to time.	The same should be IS : 335 – 2018.	Please refer corrigendum-2 Clause 2.0 APPLICABLE STANDARDS
2	3.9	Type Tests (if applicable)	Please remove - (if applicable)	Type tests are mandatory
3	4.6	Reverse Auction	Not feasible for small quantity	Adhere Tender T&C
4	7.1 (1st Bullet)	Rate shall remain FIRM till the validity of Rate Contract.	Rate shall be variable as per IEEMA PVC clause.	Adhere Tender Clause 2.1 Price Variation Clause.
5	7.1 (1st Bullet)	Rate contract shall be valid for a period of 1 years from the placement of Contract	Specific Delivery Schedule : [We would like to deliver in 3 Lot (105 Barrels X 209Liter = 21,945Liter , as this will be convenient for us.]	Acceptable
6	7.5 (Payment Terms)	The payment shall be released within 30 days from the date of submission of certified bills/ invoices		Payment shall be released within 30 days
7	Anexure I (Schedule of Items)	HSN Code	HSN Code (8 digit Code)	It should be 8 Digits for proper tracking .
8	Technical Specification (4.GENERAL TECHNICAL REQUIREMENTS - 5/b)	BDV of oil sealed drum within 4 months - 60 KV (rms) (Dielectric properties should not change in sealed drums stored as per OEM recommendation)	AS per IS recommended limit is 30 KV RMS for material delivered in Drums.	Shall be as per relevant IS Specification.
9	Technical Specification (6. Name Plate & Marking)	"PROPERTY OF TPCODL, BBSR".	"PROPERTY OF TPCODL, BBSR".	"Property of TPCODL"
10	Technical Specification (6. Name Plate & Marking)		Please include i) New mineral insulating Oil TYPE II Uninhibited Oil ii) ISI Certification mark as "IS-335-2018", iii) License No.	Please refer corrigendum-2
11	Technical Specification (6. Name Plate & Marking)	A marking required on Top cover of container stating "Kindly ensure BDV of oil from drum before every use/filling".	Not feasible as after stenciling the Oil Type, IS Mark, License No. ,Manufacturing Date, Company Logo & Brand Name, not that much space left over on top of barrels.	Required
12	Technical Specification (7.1 Type test / A. Function (8) Particle Content)	Particle Content (>4Micron) - As observed in Test	As per IS 335 : 2018 Interfacial Tension - No General Requirement	Tender clause Stands
13	Technical Specification (7.1 Type test / B. Refining & Stability (11) Interfacial Tension)	Interfacial Tension - As observed in test	As per IS 335 : 2018 Interfacial Tension - No General Requirement	Tender clause Stands
14	Technical Specification (7.1 Type test / D. Health , Safety & Environmental (22) Stray gassing)	Stray gassing - (Blank)	Not as per IS 335 : 2018 Standard.	Tender clause Stands
15	Technical Specification (7.2 Routine test)	Routine Test - Bidder should test at his own factory at least Two oil sample per lot in Routine test to comply with IS 335.	only one sample will be tested	Tender clause Stands
16	Technical Specification (7.3 Acceptance test)	The two long duration test can be started remotely through video conferencing with visiting inspector such that end results can be checked during actual plant visit.	This test shall be done from any unit of CPRI and ERDA, as Video conferencing for such long duration is not feasible. Dispatch clearance will be issued only after getting the result from CPRI/ERDA.	Please refer corrigendum-2
17	Technical Specification (10. INSPECTION AFTER RECEIPT AT STORE)	The material should be delivered at TPCODL stores within 45 days from the date of manufacturing, same shall be checked during delivery and overdue material shall not be accepted. Bidders to plan the delivery accordingly.	Material will be delivered at TPCODL Stores within 45 Days of date of Dispatch Clearance.	Tender clause Stands
18	Technical Specification (11. Guarantee)	Material supplied (Oil in Sealed barrels) will have 4 months of guarantee (all test within limit including water content limit) and 18 months guarantee (all test with in limit and water content limit 60ppm)	Material supplied (Oil in Sealed barrels) will have guarantee as per Tolerance Limit of all test.	Tender clause Stands
19	Technical Specification (12. PACKING AND TRANSPORT (1))	steel drums of 210 liters nominal capacity	steel drums of 210/209 liters nominal capacity, with the drum weight of 21KG (Min).	Accepted
20	13.2	Guarantee Period In case of no mention of the guarantee period in standard specifications or SCC Guarantee Period will be 60 Months from the Date of Commissioning or 72 months from the date of delivery of final lot of supplies made, whichever is earlier.	12 Months from the Date of Commissioning or 18 months from the date of delivery of final lot of supplies made, whichever is earlier.	Adhere clause No.11 of Technical specification
21	As per clause no.7.3 of technical specification	SAMPLING AND TESTING OF OIL SAMPLE:-Oxidation stability test shall be done from any unit of CPRI and all the cost shall be borne by the manufacturer. Dispatch clearance will be issued only after getting the result from CPRI.	Please note that the testing time taken by CPRI/ERDA are not under our control and hence any delay in delivery will not be to our account.	Bidder needs to ensure timely delivery by following up with testing Agency
22	GENERAL TECHNICAL REQUIREMENTS (b)	BDV of oil sealed drum within 4 months	We commit limit as specified in IS 335 :2018 standard i.e 30 kv min. as received.	Tender clause Stands .