

Format for Pre-Bid Queries

Tender No : TPCODL/P&S/1000000336/2022-23

Package Name : Open Tender Notification for Rate Contract for Supply of Transformer Oil

Bidder :

Pre-Bid Query has to be sent in editable Excel file format only

Pre-Bid Query has to be sent through e-mail or SAP Ariba

Sr. No.	Detailed Reference to Tata Power Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPCODL RESPONSE
1	2	3	4	5
1	2.1	P0 = Price (in Rs / KLtr) quoted/ confirmed for the transformer oil supplied in drums and confirming to IS : 335-1993 and amended from time to time.	The same should be as per IS : 335 – 2018.	As per Latest Amendment only
2	7.1 (1)	Rate shall remain FIRM till the validity of Rate Contract	Rate shall be variable as per IEEMA PVC clause.	Accepted. Rate Shall be Variable as per IEEMA Only
3	7.1	Rate contract shall be valid for a period of 1 year from the placement of Contract	We will prefer to deliver the total quantity in Maximum 2 (Two) lots as this will be convenient to us.	Accepted
4	13.2 Guarantee Period	In case of no mention of the guarantee period in standard specifications or SCC Guarantee Period will be 60 Months from the Date of Commissioning or 72 months from the date of delivery of final lot of supplies made, whichever is earlier.	12 Months from the Date of Commissioning or 18 months from the date of supply made, whichever is earlier.	Accepted
5	13.6 Latent Defect	Associates shall further be responsible for 'free replacement' for another period of THREE years from the end of the guarantee period for any 'Latent Defects' if noticed and reported by the Company.	Please note that this clause of Latent defect is not applicable to transformer oil.	OKAY
6	Clause 4.5.(b) of technical specification	BDV of oil sealed drum within 4 months :- 60 kV (rms) (Dielectric properties should not change in sealed drums stored as per OEM recommendation)	BDV of 60 kV can be achieved but we cannot guarantee the same. It depends upon handling & storage of drums , sampling etc. We commit limit as specified in IS 335 :2018 standard i.e 30 kV min. as received	Accepted
7	Clause 6 Name plate & marking of technical specification	A marking required on Top cover of container stating "Kindly ensure BDV of oil from drum before every use/filling".	We will provide the same on first band of drums	OKAY
8	Clause 7.1 Type test of technical specification	Particle content > 4 micron	No limits specified in IS 335:2018 standard & also we don't have test facility to test and report.	OKAY
9	Clause 7.1 Type test of technical specification	Stray gassing	This parameters is not provided in the table f IS 335:2018 standard. We cannot provide the type test report.	OKAY

10	Clause 7.3 Acceptance test- of technical specification	The BDV shall be >70 at the time of inspection and water content below 40 ppm.	We commit for Min. 50 kV during inspection.	Accepted
11	Clause 9 PRE-DISPATCH INSPECTION	If during inspection any observation recorded same to be addressed by manufacturer at earliest and compliance report to be shared to quality department of TPDDL.	PLEASE SPECIFY	During inspection if any variance came wrt spec, then it is to be addressed at earliest and compliance report needs to be sent to TPCODL quality dept.
12	Clause 11 Guarantee	Material supplied (Oil in Sealed barrels) will have 4 months of guarantee (all test within limit including water content limit) and 18 months guarantee (all test with in limit and water content limit 60ppm)	Complied (Confirm all limits will be within in the IS 335:2018 Type II standard)	OKAY
13	As per clause no.7.3 of technical specification	SAMPLING AND TESTING OF OIL SAMPLE:-Oxidation stability test shall be done from any unit of CPRI and all the cost shall be borne by the manufacturer. Dispatch clearance will be issued only after getting the result from CPRI.	Please note that the testing time taken by CPRI/ERDA are not under our control and hence any delay in delivery will not be to our account	OKAY
14	Technical Specification (12. PACKING ANDTRANSPORT (1))	steel drums of 210 liters nominal capacity	Our drum capacity is 210 litres however Our standard packing is 209 litres We will fill 209 litres in one drum	OKAY
15	Technical Specification (10. INSPECTION AFTER RECEIPT AT STORE)	The material should be delivered at TPCODL stores within 45 days from the date of manufacturing, same shall be checked during delivery and overdue material shall not be accepted. Bidders to plan the delivery accordingly.	Material will be delivered at TPCODL Stores within 45 Days of date of Dispatch Clearance.	We need this oil asap. So 45days from dispatch clearance will not be acceptable. Adhere to the Tender Clause
16	Technical Specification (7.3 Acceptance test	The two long duration test can be started remotely through video conferencing with visiting inspector such that end results can be checked during actual plant visit	This test shall be done from any unit of CPRI and ERDA, as Video conferencing for such long duration is not feasible.	OKAY