

Pre-Bid Response against Tender No : TPCODL/P&S/1000000371/2023-24			Date of Response- 06.05.2023	
Package Name : Rate Contract for Supply of Trolley Mounted Distribution Transformer (MOBILE Sub-Station 11/.4 KV 500 KVA)				
Sr. No.	Detailed Reference to TPCODL Technical Document. Specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPCODL RESPONSE
1	2	3	4	5
1	General	HT RMU	Kindly Confirm Number of Incoming and Outgoing in RMU. Also please confirm Whether RMU shall be Motorised or Manual. Accordingly Please provide use of HRC Fuse	RMU is not required. We require LBS with HT Fuse
2	General	LT SIDE EQUIPMENT	Kindly Confirm 2 Nos 400 AMP MCCB required for LT Side for 500 KVA DT. There is no need of ACB	ACB is not required. We require 2 Nos of 400 Amp MCCB
3	Page No.95, Point No.5 (f),	Cable Relaying Drum (Manual)	We understand Cable Relaying Drum for HT and LT Cable shall be mounted/fixed Inside Compact Substation on respective voltage side	Preferable
4	NA	NA	Completion / Delivery period is not specifically mentioned in the tender document. Kindly clarify the delivery/ completion period or mention the page no. if already mentioned in the tender document.	90 days from the date of CAT-A approval or, placement of RO whichever is later.
5	2.1 Price Basis:	Price shall remain FIRM throughout the contract. PV not applicable.	As this is rate contract for the period of 1 year also bid validity is 180 days. It is very difficult to quote firm price for such long	PV Not Applicable. PRICE Shall remain FIRM

6	3.5 Period of Validity of Bids	Bids shall remain valid for 180 days from the due date of submission of the bid.	quote firm price for such long period. Hence we request you to kindly accept the price variation clause, IEEMA PVC without ceiling	Bid shall be valid for 180 Days from the date of submission of the bid
---	--------------------------------	--	--	--

Pre-Bid Response against Tender No : TPCODL/P&S/100000371/2023-24			Date of Response- 06.05.2023	
Package Name : Rate Contract for Supply of Trolley Mounted Distribution Transformer (MOBILE Sub-Station 11/4 KV 500 KVA)				
Sr. No.	Detailed Reference to TPCODL Technical Document. Specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPCODL RESPONSE
1	2	3	4	5
7	7.1. Special Conditions of Contract	Rate contract shall be valid for a period of 01 Year from the placement of Contract. Release Order (RO) shall be placed as per the requirement of TPCODL. The Rate shall remain FIRM throughout the Contract.	As this is rate contract for the period of 1 year also bid validity is 180 days. It is very difficult to quote firm price for such long period. Hence we request you to kindly accept the price variation clause, IEEMA PVC without ceiling	Rate Contract shall be for 01 Year. Requirement is for 05 nos. Qty. We shall try to place order for the Quantity intended considering the market fluctuations
8	7.1. Special Conditions of Contract	Terms of Payment: On delivery of the materials in good condition and certification of acceptance by certified official, Associate shall submit the Bills/ Invoices in original in the name of TP Central Odisha Distribution Limited to Invoice Desk. The payment shall be released within 45 days from the date of submission of certified bills/ invoice	We being MSME Vendor, would like to have bill discounted through TREDS Platform.	TREDS Discounting is Applicable. The same can be done post finalization of the Contract.
9	7.1. Special Conditions of Contract	Business Associate (BA) shall submit applicable Performance Bank Guarantee as per GCC within 15 days of issuance of rate contract or, release order. PBG applicable shall be @5% of Rate Contract Value or, 10% of Release Order Value. Validity of of BG shall be till expiry date of RC plus delivery period plus warranty period in case of 5% value BG. Validity will be till delivery period plus warranty period for 10% value BG.Claim period will be additional one month for both cases.	We request you to accept CPBG OF 3% as per recent circular issued by Government of India- Ministry of Finance dated 12th Nov 2020.	PBG shall be 5% of the rate contract value only. Clause shall be as per Tender Document only.

Pre-Bid Response against Tender No : TPCODL/P&S/100000371/2023-24			Date of Response- 06.05.2023	
Package Name : Rate Contract for Supply of Trolley Mounted Distribution Transformer (MOBILE Sub-Station 11/4 KV 500 KVA)				
Sr. No.	Detailed Reference to TPCODL Technical Document. Specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPCODL RESPONSE
1	2	3	4	5
10	1.7 Qualification Criteria	Bidder must furnish valid all the type test report of individual equipment (DT, RMU, LT, ACB etc.) carried out at CPRI/ERDA. The bidder or the OEM for the Distribution Transformer should have valid BEE certification to manufacture Star Label Transformers with successful Type Test Report (TTR) conducted from CPRI / ERDA for the Distribution Transformer for the offered Transformer and shall furnish the same as a part of the Technical Bid. The type tests should have been conducted on the equipment / material of the same design. The type tests should have been conducted within 5 years prior to the date of bid opening. Time period for type test can be extended by another 5 years as a special case, if there is no change in design / material of construction (MOC). Offers with valid Type Test Reports of vital equipment shall only be considered for evaluation. Non submission of type test reports will lead to rejection of the offer.	We shall submit the Type Test Reports for the similar/Higher rating. Design will be the same for offered transformer.	Higher Rating TTR is not accepted. Please arrange for TTR of the same rating.
11	Technical Specification for Trolley Mounted Distribution Transformer	Reference: *ENG-HV-2002:- Technical Specification for 11/0.4kV 250kVA to 2000kVA Distribution Transformer (Cu) **ENG-LV-3016:- Specification of 400,630,800 Amp ACB with Enclosure (Outdoor Application) Above Technical specification shall be provided to bidder along with tender documents	Could't find Technical specifications. Please provide the same. We are not able to proceed further because of incomplete technical specifications. Also extend the due date for pre bid queries so that we can submit the technical queries if any.	*DT specs shall be shared in Corrigendum **ACB Specification is not applicable