

Tender No : TPCODL/P&S/1000000471/2023-24		
Package Name : SITC of LTACB & Busduct		

Prebid Query Reply				
Sr. No.	Detailed Reference to TPCODL Tender document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	TPCODL RESPONSE 14.11.2023
1	2	3	4	5
1	1.1	Scope of work	Please confirm if we can participate supply portion of work (SL NO 1 to 4)	Complete scope shall be as per tender. No deviation shall be accepted from tender
2	4.2	Panel and ACB shall be fully type tested.	Please consider PTTA Panel As per IEC 60439.	Shall be as per tender specification
3	4.2	ABB/SIEMENS/SCHNEIDER/L&T/LEGRAND (Preferred)	Please consider Mitsubishi Make also for us to offer IEC 61439 TTA Panel.	Shall be as per tender specification
4	SINGLE LINE DIAGRAM (ANNEXURE-1)	CT 4000/5/5A, 0.5S,PS,5P20	Please provide the Knee point voltage for PS class CT	PS Class CT Not Required
				Revised Single Line Diagram for 4000A LT ACB Panel is attached

SINGLE LINE DIAGRAM

