

Tender No. TPCODL/P&S/100000541/23-24 for "Engineering, Supply, Installation Testing and Commissioning of River Crossing work on Turnkey Basis"

Pre-Bid Queries

S. No.	Clause no	Description	Bidders query / Clarification	TPCODL Response / Modification
1		Locations of River Crossing	Please provide tentative locations where river crossing work will take place.	Across TPCODL area which included 5 Circle & 20 Division (BBSR-1, BBSR-2, Cuttack, Dhenkanal, Paradeep)
2		Technical specification of Following Material /Equipment	Request to provide Technical specification of the Material /Equipment.	
		14 Mtr. Long H-Pole		Specification Attached
		232 mm ² AAAC		Specification Attached
		H.T. Stay set (Complete)		Specification Attached
		H.T. Stay Insulator Type-C (2 No's.)		Specification Attached
		7/8 SWG Stay Wire 15kg /stay		Specification Attached
		33 KV 1250 AMP Double break (Turn & twist center rotating) isolator without earth switch with PI(Polymer)		Specification Attached
		For PC+6 and UR+6 Tower		
		Earth wire 7/1.5 G.I		Specification Attached
		Double tension Hardware Fittings suitable for conductor size		Specification Attached
		Tension fittings suitable for Earth wire.		Specification Attached
		Vibration damper suitable for earth wire		Specification Attached
		Vibration damper suitable for conductor size.		
		Circuit Plate		Specification Attached
		Earthing Device & Associated Accessories (Heavy duty GI Perforated Pipe of ID=40mm & OD=50mm with 3000mm long for treated Earth Pit), as per technical specification and scope of work.		Specification Attached
		Bird Guard		Specification Attached
		Anticlimbing Device (G.I)	Specification Attached	
		Loop Connector	Specification Attached	

Tender No. TPCODL/P&S/100000541/23-24 for "Engineering, Supply, Installation Testing and Commissioning of River Crossing work on Turnkey Basis"

Pre-Bid Queries

S. No.	Clause no	Description	Bidders query / Clarification	TPCODL Response / Modification
	7.1.8	<p>CONTRACT PERFORMANCE BANK GUARANTEE: The successful Bidder shall be required to furnish two Contract Performance Bank Guarantee in non-judicial stamp paper of appropriate value (as per the prescribed format) issued in favour of "TP Central Odisha Distribution Ltd." encashable at Bhubaneswar Branch of the Issuing Bank only within 30 (Thirty) days from the date of issue of the Release Order. First BG : The Contract Performance Bank Guarantee (CPBG) amount shall be equal to Five percent (5%) of the Contract Price (including GST) of each Release Order related Major items i.e (13 Mtr/14 Mtr. H Pole, Isolator, PC+6 Tower, UR+6 Tower, AAAC Conductor etc.) valid for 03 (three) Months over and above work completion period (SITC) plus Guarantee Period i.e. (6 months (SITC) + 60 Months (Guarantee Period)+3 Months (Claim Period) = 69 months).</p> <p>Second BG : The Contract Performance Bank Guarantee (CPBG) amount shall be equal to Five percent (5%) of the Contract Price (including GST) for each Release Order related minor items (excluding cost of major items as above) valid for 03 (three) Months over and above work completion period (SITC) plus Guarantee Period i.e. (6 months (SITC) + 24 Months (Guarantee Period) +3 Months (Claim Period) = 33 months).</p>	<p>The performance guarantee period in other organisation(OPTCL) is 18 months from the date of supply and 12 months from the Date of Commissioning which ever is earlier .The Same has been applied to us in Daya River crossing work under TPCODL against PO NO.350000584 Dtd.04.03.2023. We are requesting you to consider the same in this above tender.</p>	<p>Pls adhere the contract T&C</p>