

Pre-Bid Clarification

Tender Reference No

TPCODL/P&S/155/20-21

Tender Name

Rate contract for supply of Cross Arm, Insulators, Hardware & LA of OH Line

Sr. No.	Detailed Reference to Tata Power Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	Tata Power Response
1	2	3	4	5
1	PAGE NO. 91 (DRAWING)	11KV V-CROSS ARMS, TOP BRACKET & BACK CLAMP	LENGTH of 9Mtr PSC Pole, 10Mtr PSC Pole & 150x150mm JOIST is given with size. Kindly Confirm in Price Bid PRICE of Which Size is to be quoted.	To be quoted as per specification mentioned under "Technical Specification" page 91(drawing) : 9mtr Qty. to be 70 % and 10 mtr qty to be 30 % of total qty. mentioned in price bid. Accordingly, qty for Back Clamp- joist and top bracket to be considered for both 9mtr and 10 mtr pole. Order Actual quantities may vary as per requirements during contract period, Release Orders shall be placed against the awarded Rate Contract by TPCODL as and when the requirements arises.
2	PAGE NO. 128 -138 (DRAWING)	70KN 3Bolted HWF	From Page No. 128-138 all Drawings have mentioned of 11kv / 33kv 70KN 3Bolted and 2 bolted HWF. Kindly confirm Price of Which Page no. Drawing is to be given.	To be Quoted for 3 Bolted 70 KN
3		70KN B&S DISC INSULATOR	As GTP & DRAWING of the same is not provided in the Tender Document. Hence we hereby giving the attachment of GTP & Drawing. (B&S and T&C) TYPE .Kindly give approval & confirm which type the Price (B&S and T&C) is to be given.	B&S Disc Insulator: As per specification mentioned in Tender Pg no.103-113. To be quoted for B&S type. Approval of Drawing will be done during technical evaluation
4	PAGE NO. 93 , 1.0 SCOPE & PAGE NO. 98	11KV POST INSULATOR	It is Mentioned that it shall be porcelain/composite type Post insulators. But in Page No. 98 only GTP of porcelain Type Post Insulator is Given. Hence we hereby giving the attachment of GTP & Drawing of Composite type Post insulator. Kindly give approval	To be quoted for Porcelain
5		11KV PIN INSULATOR	As GTP & DRAWING of the same is not provided in the Tender Document. Hence we hereby giving the attachment of GTP & Drawing. Kindly give approval.	Bidder may submit the bid as per GTP provided. Approval of drawing and specs will be done during technical evaluation
6	PAGE NO. 142	LT SACKLE INSULATOR	GTP is mentioned for both Medium & Large type of Insulator. Kindly confirm Price of which type is to be quoted in the Price Bid.	Large type
7	PAGE NO. 127	GI PIN FOR LT PIN INSULATOR	As the Mentioned Size is not the Regular size & we have to balance the Production Cost. Hence the Order quantity should be minimum of 2000 Pcs in a single Order.	Order Qty to be as mentioned in tender requirements.